

PUBLIC HEALTH ENGINEERING DEPARTMENT WATER TESTING LABORATORY, JIND

Lab. No: -PC27/2020

1. Sender's Address : Maharishi Vidya Mandir Sr. Sec. School,
Rohtak Bye Pass Road, Jind.
2. Source of Sample : Water Sample for R.O.
3. Collected on : 14.05.2020
4. Received on : 14.05.2020
5. Ref. No. : 1229 -
6. Sample Submitted by : Sh. Rajesh

Dated: - 14.05.2020

Memo No:- 521

Dated :- 20/05/2020


Chemical Analysis Report


Sr. No.	Substance/Characteristic	Result	Desirable Limit	Maximum Permissible Limit (In Absence of Alternate Source)
			As per IS:10500-2012 (second Revision)	
1.	Total Dissolved Solids, mg/l	144	500	2000
2.	Total Hardness, mg/l	30	200	600
3.	Calcium (as Ca), mg/l	8	75	200
4.	Magnesium (as Mg), mg/l	2.4	30	100
5.	Alkalinity, mg/l	80	200	600
6.	Chloride (as Cl), mg/l	85.2	250	1000
7.	Sulphate (as SO ₄), mg/l	12	200	400
8.	Fluoride (as F), mg/l	0.08	1.0	1.5
9.	Iron (as Fe), mg/l	0.01	1.0	No relaxn.
10.	Nitrate (as NO ₃), mg/l	0.2	45	No relaxn.
11.	pH value	7.02	6.5-8.5	No relaxn.

*Reliability of sample lies with the collector/sender. The Sample was not collected by this lab.

OPINION

The above mentioned analysis of water sample does meet the requirement of IS: 10500-2012 (Second Revision).


Principal
Maharishi Vidya Mandir Sr. Sec. School
Rohtak Bye Pass Road, Jind


Chemist,
Public Health Engineering Deptt.
Water Testing Laboratory, Jind

HEALTH DEPARTMENT DISTRICT JIND



Hygienic Certificate

Certified that Dy Civil Surgeon Jind (Health) O/o Civil Surgeon Jind inspected the premise report of Maharishi Vidya Mandir Jind on Dated 21-05-2020 and found hygienic and sanitation condition of this School Satisfactory for the year 2020-2021

Dr. 17/6/2020
Dy, Civil Surgeon (Health)
For Civil Surgeon Jind
(Signature)

Memo No. AUO/CSJind/2020/159
Dated. 16-06-2020

(Signature)
Principal
Maharishi Vidya Mandir Sr. Sec. School
Rohtak Bye Pass Road Jind-128102